



Project Name:	Contract/SWLE #
Inspector:	Page:            of
Contractor:	Date:

From	To	Pipe Diam. (in.)	Pipe Length (ft.)	Design Working Pressure (psi)	Test Pressure (psi)*		Test Time (hr:min)	Pass	Fail	Remarks
					Start	Finish				

\* All pressure pipelines and appurtenances shall be hydrostatically tested for a duration of not less than 2 hours, at the greater of 150% of the design working pressure or 100-psi hydrostatic pressure.

---

Inspector Signature
Date